





- 47% of the incoming radiation from the sun is absorbed by the earth
- The remainder is absorbed by the atmosphere or reflected back into space
- Translated: Geo-Thermal means "Earth-Heat"
- "High Temperature" Geothermal Energy
 - Energy Source for Hot springs and geysers
 - Temperatures exceed 300°F
 - Converted to produce useable heat and electricity










































Pond Loop


- Most <u>Cost Effective</u> closed loop design
- Pond Depth 12 15 ft minimum maintained depth
- Pipe Length One 300 ft. coil per ton (minimum)
- Capacity 10 to 20 tons/acre of pond

























Energy Consid	eratio	15		
Heat Pumps – G	round So	ource		
Heating Efficiency me	easured by CO	OP (Coefficie	ent of Perform	nance)
 Cooling Efficiency me 	easured by El	ER (Energy E	fficiency Rat	tio)
	•			
Efficiency measured	at Specific Te	mperatures	and Conditio	ns
• •	at Specific Te	mperatures	and Conditio	ns
Efficiency measured			1	
• •		d Loop EER @ 77°F	1	ns Loop EER @ 59°F
Efficiency measured Efficiency Rating	Close	d Loop	Oper	n Loop
• Efficiency measured Efficiency Rating ARI / ASHRAE / ISO 13256 - 1	Close COP @ 32°F	d Loop EER @ 77°F	Oper COP @ 50°F	Loop EER @ 59°F
















ergy Consideratio	ns
ump Energy Report Car	ď
sy Stephen Kavanaugh, PhD	
Pump Power per 100 tons	Grade
5 or Less	A – Excellent
5 to 7.5	B – Good
7.5 to 10	C – Mediocre
10 to 15	D – Poor




















































uildings Range \$ 1.88 - \$ 4.55	Average
	Average
¢100 ¢155	
ə 1.00 — ə 4.00	\$ 3.27 / SqFt
\$ 715 – \$ 2,817	\$ 1,719 / Ton
\$ 775 – \$ 3,032	\$ 1,537 / Bore
\$ 4.43 - \$ 12.50	\$ 7.83 / BoreF
construction costs	
ope or normalized for condit	tions
Boilers, Chillers, Cooling Tov Dany Incentives	wers
	\$ 775 – \$ 3,032 \$ 4.43 – \$ 12.50 Construction costs ope or normalized for condit Boilers, Chillers, Cooling Too














Lincoln Sc	hools, Lincoln	Nebraska		
	and Total Annual Mai	ntenance Costs per So		\frown
Average	PM Costs, Repair, Service	, and Corrective Action C	osts, and Total Maintenan	ceCosts
School	Preventive Maintenance Costs per Year per ft ² (¢/yr·ft ²)		Total Maintenance Costs per Year per ft ² (¢/yr·f ²)	Total Maintenance Cost per Year per Cooling ft (¢/yr·cool ft ²)
				1
Geothermal Heat Pumps (vertical bore)	7.14	2.13	9.27	9.27
	5.87	2.13	9.27 8.75	9.27
(vertical bore) Air-Cooled Chiller and	10145-022			



